



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 11/17/09

Code 48.13.4.9

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY- ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title 408.3 Unvented Crawl Space		Page 1
Proponent SW Indiana Builders and Building Officials	Title	
Address 2175 N Cullen Ave; Evansville, IN 47715 Center Complex; Room 310; Evansville, IN 47708		Phone 812-479-6026 812-436-7868
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution PROPOSED CODE CHANGE (Check One)		
Insert 2.2 to read as follows: "Conditioned air supply sized to deliver at a MINIMUM rate equal to 1 cfm for each 50 sf of under-floor area and perimeter walls insulated in accordance with Chapter 11." Re-number other items in 49.1-09R as 2.3 and 2.4.		
REASON		
This amendment would be in line with the 2000 IRC model, the 2003 IRC model, and current 2005 Indiana Code, and 2009 model with the exception of not allowing the supplied air to return to the living areas. This practice has been proven successful and effective in Indiana's most humid climate, resulting in dry and dusty crawlspaces. This amendment adds "minimum" because we have prevented problems in a significant number of complicated situations by simply increasing the amount of conditioned air. The amendment removes any "return" to remove even remote possibilities of health issues.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		